

Additional Funding Request

Site: NY023	WO#21058 CSS # 91833
Description of Repairs	Boiler water circulating pump dying and the woods coupler broke off. The pump needs to be replaced as well as the coupler and coupler guard. Will be replaced with Dayton stock motor.
Diagnosis: Initial Work Order	AMSA12 is experiencing low heat in the bays requiring a diagnostic check and check street pressure valve in the boiler room
Explanation of Additional Costs for Repairs	
Additional Labor Cost to Perform Repairs	510.00
Additional Material Cost to Perform Repairs	1985.71
Total Cost of Repair	\$2495.71

WORK ORDER ESTIMATE

CSS #: 91833

Work Order #: 21058

Emergency ☐ Urgent ☐ Yes ☐ Routine ☐

Company Name:	ISG	Facility ID:	NY023
Contractor POC:			
Telephone No:		Building/Location; (e.g., Classroom/Room #)	Building 123/Boiler Room
E-Mail Address:			
Assigned Technician(s):	Deen Rowe		

DESCRIPTION of WORK and EXPLANATION for REPAIRS or REPLACEMENT

AMSA12 is experiencing low heat in the bays requiring diagnostic check and check street pressure valve in boiler room

Boiler water circulating pump dying and woods coupler broke off. Pump needs to be replaced as well as coupler and coupler guard.

LABOR/MATERIAL		MATERIAL/SUB UNIT DOLLAR AMOUNT	LBR/HR \$85.00	LINE ITEM TOTAL DOLLAR AMOUNT
ITEM	QUANTITY			
Tire Coupling Hub	2	172.12 x 20%		\$413.08
Dayton Pump Stock Pump	1	1081.48 x 20%		\$1,297.77
Tire Coupling Element	1	229.05 x 20%		\$274.86
	6	85.00 per hour		\$510.00
SUB-TOTAL COSTS:		Materials Total	\$1,985.71	Labor \$510.00
TOTAL			\$2,495.71	

