

SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: Ft. Totten, NY NY058 Date of Visit: 4/6/2023
Building 206
Contractor Personnel on Site:

1. Nicholas LoRusso
2. Matthew LoRusso
3. _____
4. _____
5. _____
6. _____

Service Call Number

CSS# 92742 WO# _____

Description of Repairs

Replaced weather proof push to exit button,
Weather proof 1200 lb maglock, \$2 bracket on
Building 206 Main Gate.
Tested gate, Gate functioning and back
in service.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Nicholas LoRusso Date: 4/6/23
Signed: Nicholas LoRusso

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Peter Comito AFOS Date: 04/13/23
Signed: Peter Comito

E-Mail: peter.d.comito.ctr@army.mil

