

NYC-DEP

Form for Report on Test and Maintenance of Containment Backflow Prevention Assembly

Bureau of Water and Sewer Operations

Please use a separate form for each assembly

Part A- TO BE COMPLETED IN ALL CASES

Initial Test

Complete entire form

Annual Test – For the Year 2022

Complete Parts A & B Only

Public Water Supply: NYC-DEP	County: QUEENS	Block:	Lot:	<u>Department Use Only</u>
Name & Address of Facility: Asset 9400		Make & Model # of Assembly		
US ARMY BLDG 124		WATTS 709DCDA		
FORT TOTTEN		Size & Serial # of Assembly		
BAYSIDE NY		6"	127522	
Location (Floor) of Assembly: FIRST FLOOR SOUTH WALL				

Part B- TO BE COMPLETED BY NYS CERTIFIED BACKFLOW PREVENTION ASSEMBLY TESTER

Procedure	Check Valve No. 1	Check Valve No. 2	Differential Pressure Relief Valve (RPZ only)	Line Pressure 55 psi
Test Before Repair	Pressure drop across first check valve, psi _____	Leak Closed tight () Closed tight (X)	Opened at _____ psi	Date: 08 / 30 / 2022
	Leak Closed tight () Closed tight (X)			
Describe repairs, parts and materials used.				Name of Repairer: DANIEL VESSIO #1378 Name, Lic. # & Seal of Master Plumber.
Final test	Pressure drop across first check valve, psi _____	Closed tight ()	Opened at _____ psi	Date: _____ / _____ / _____
	Closed tight ()			
Water Meter Number: 09007842	Meter Reading: 00048.00	Completion Time of Test (e.g. 3:15 pm): 8:15AM	Type of Water Service/System (Please Check One): () Domestic (X) Fire () Combined () IWM	

Question 1: Are there any connections between the point of entry and the backflow prevention assembly, or other deficiencies? NO (X) YES () *If YES, please explain in detail in the space provided or on an additional paper.*

CERTIFICATION: This assembly meets the requirements of an acceptable containment assembly at time of testing.
I hereby certify the foregoing data to be correct.

Signature

8/30/22
Date

CERTIFICATION: This assembly does NOT meet the requirements.

Signature

____ / ____ / ____
Date

DANIEL VESSIO
PRINT NAME

(718) 459 - 1223
Telephone No.

921
Certified Tester No. 06 / 30 / 25
Expiration Date

Part C- TO BE COMPLETED BY NYS PE OR RA

Professional Engineer's or Registered Architect's Certification:

I have personally checked this installation and I certify that it is in accordance with the approved plans.

NYC-DEP Backflow Prevention Assembly Approval #:

[] I am the Designer of Record. [] I am NOT the Designer of Record.

PE/RA Printed Name:

Company:

Address:

Telephone #:

Signature, Seal & Date:

Minor Installation Changes (describe): (Attach additional sheets if required)

Part D – TO BE COMPLETED BY NYC LICENSED MASTER PLUMBER

Master Plumber's Certification: [] I am [] I am NOT the Licensed Master Plumber of Record. I have personally checked this installation and I certify that it is in accordance with the Building Department's Requirements.Building Department Number:
(Use Sticker)

Plumber's Printed Name:

Plumber's License #:

Telephone #:

Signature, Seal and Date:

NOTE: Send one completed form, within 30 days of installation and initial testing, with original ink signatures and original ink or impressed seals to

NYC-DEP-BWSO, Cross-Connection Control Unit, 59-17 Junction Blvd., 3rd Fl. Low-Rise, Flushing, NY 11373