

BUILDING 123

3 Boilers...2 -TRIAD Boilers model EOPS-1600 SH

with Power Flame Burners Model CR2-GO-20B

1-AO Smith Boiler model COBT 300

with a Power Flame Burner Model CR1-GO-10

All boilers code compliant, boiler room code compliant

Condition good.

BUILDING 128

2 Boilers ...2-HB Smith model 19HE-04

with Power Flame Burner Model LNICR1-G-10

All boilers code compliant,

Heating pipe needs to be insulated.

Boiler room has violations, needs to be sealed. The ceiling has holes.

Boiler condition is good.

BUILDING 206

4 Boilers...3-ATH (Advanced Thermal Hydronics) model KN4

1 ATH (Advanced Thermal Hydronics) model KN2

One boiler requires a top access cover.

Other boilers are code compliant and in good condition.

Boiler room is compliant

BUILDING 319

1 Boiler...1-Weil McLain Model 780

BUILDING 319 Continued...

With a Carlin Burner model 702 CRD

1 Hot water Heater...Bock model 51E

With a Carlin Burner EZ-1

Boiler and Hot water heater are code compliant and are in good condition

Heating pipe in the boiler room needs insulation.

Barometric (6 inch) air damper needs to be moved on the water heaters exhaust
Vent.

The electrical outlets in the boiler room needs to be GFI type.

BUILDING 330

"A" side

2 Boilers...1-HB Smith 28 Series Model HE-8

with a Carlin Burner 801.

1-Slant Fin Boiler EC-16p

with a Riello Burner model 40

Both boilers are code compliant and are in good condition

Boiler room needs general clean up.

"B" side

2 Boilers ...1-HB Smith 28 Series Model HE- 8

With a Carlin Burner 801.

1 Slant Fin Boiler EC-16p

With a Riello Burner model 40

Both boilers are code compliant and are in good condition.

BUILDING 330


"B" side continued...

Boiler room need general clean up


Remove cardboard boxes.

Total boilers inspected 21.

Respectfully,



Daniel D. Vessio



CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY023

Date of Visit: 9/10/19

Contractor Personnel on Site:

1. I WORK

2. DAN VESSTO


Work Performed:

Preventive Maintenance -(Annual, Quarterly, Monthly, equipment identification, etc.)
Service Orders -

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: John Woleck Date: 9/10/19

Signed: 

To be signed by Facility Manager:

I certify that the above named individuals representing the Contractor arrived on site and to the best of my knowledge, completed the stated work listed:

Print Name/Rank: Louis CORBO Date: 9/10/14

Signed: Louis Corbo

E-Mail: Louis-A.CORBO-ctr@mail.mil