


PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FAN COIL UNIT

SITE AND BLDG #: **NY030N01****MECHANIC****SIGNATURE:** James R Groft Jr**DATE:** 07/30/2025**LOCATION/RM #:****WO# 19381****ASSET #4462****START TIME:****FINISH TIME:**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.	X		RM 205,207, & 213 not functioning correctly
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check fan blades for dust buildup and clean if necessary.	X		
2	Check fan blades and moving parts for cracks and excessive wear.	X		
3	Tighten all electrical connectors to proper torque asneeded.	X		
4	Check that the fan runs properly in all speeds as applicable.			
5	Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary.	X		
7	Lubricate mechanical connections of dampers sparingly as applicable.	X		
8	Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a CM.	X		
9	Clean coils by brushing, blowing, vacuuming	X		
10	Check coils for leaking, tightness of fittings.	X		
11	Use fin comb to straighten coil fins as needed.	X		
12	Check belts for wear and cracks, adjust tension or alignment as applicable. Replace belts when necessary.	X		
13	Check rigid couplings for alignment on direct drives, and for tightness of assembly	X		
14	Vacuum interior of unit.	X		
15	Check filter door for proper gasketing and air leaks. Correct as needed.	X		
16	Change the filter as needed with the correct size and type filter.	X		Filter gets checked Quarterly
17	Insure that drain(s) are clear and running.- Install condensate tablet	X		
18	Clean up work area. - Record Humidity level in area	X		Humidity 40 %

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: