

## PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

### FAN COIL UNIT

SITE AND BLDG #:NY052N01

MECHANIC

SIGNATURE: James R Groft JrDATE: 07/24/24


LOCATION/RM #:

WO# 16007ASSET # 4547

START TIME:

FINISH TIME:

| CHECK POINT                                       | CHECKPOINT DESCRIPTION                                                                                                                                                 | TASK COMPLETE |    | NOTES/ ACTIONS<br>(IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION) |
|---------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|----|-------------------------------------------------------------------------|
|                                                   |                                                                                                                                                                        | YES           | NO |                                                                         |
| <b>SPECIAL INSTRUCTIONS</b>                       |                                                                                                                                                                        |               |    |                                                                         |
| 1                                                 | As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times. | X             |    |                                                                         |
| <b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b> |                                                                                                                                                                        |               |    |                                                                         |
| 1                                                 | Check fan blades for dust buildup and clean if necessary.                                                                                                              | X             |    |                                                                         |
| 2                                                 | Check fan blades and moving parts for cracks and excessive wear.                                                                                                       | X             |    |                                                                         |
| 3                                                 | Tighten all electrical connectors to proper torque as needed.                                                                                                          | X             |    |                                                                         |
| 4                                                 | Check that the fan runs properly in all speeds as applicable.                                                                                                          | X             |    |                                                                         |
| 5                                                 | Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary.                                      | X             |    |                                                                         |
| 7                                                 | Lubricate mechanical connections of dampers sparingly as applicable.                                                                                                   | X             |    |                                                                         |
| 8                                                 | Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a CM.                                                                        | X             |    |                                                                         |
| 9                                                 | Clean coils by brushing, blowing, vacuuming                                                                                                                            | X             |    |                                                                         |
| 10                                                | Check coils for leaking, tightness of fittings.                                                                                                                        | X             |    |                                                                         |
| 11                                                | Use fin comb to straighten coil fins as needed.                                                                                                                        | X             |    |                                                                         |
| 12                                                | Check belts for wear and cracks, adjust tension or alignment as applicable. Replace belts when necessary.                                                              | X             |    |                                                                         |
| 13                                                | Check rigid couplings for alignment on direct drives, and for tightness of assembly                                                                                    | X             |    |                                                                         |
| 14                                                | Vacuum interior of unit.                                                                                                                                               | X             |    |                                                                         |
| 15                                                | Check filter door for proper gasketing and air leaks. Correct as needed.                                                                                               | X             |    |                                                                         |
| 16                                                | Change the filter as needed with the correct size and type filter.                                                                                                     | X             |    | Filter gets checked Quarterly                                           |
| 17                                                | Insure that drain(s) are clear and running.- Install condensate tablet                                                                                                 | X             |    |                                                                         |
| 18                                                | Clean up work area. - Record Humidity level in area                                                                                                                    |               |    | Humidity <u>43</u> %                                                    |



Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:**