

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FAN COIL UNIT

SITE AND BLDG #: **NY052N01**


MECHANIC
SIGNATURE: James R Groft Jr

DATE: **10/22/2025**

LOCATION/RM #: **WO#20238** **ASSET # 4547**

START TIME: _____

FINISH TIME: _____

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
		YES	NO	SPECIAL INSTRUCTIONS	
1	As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.	X			
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Check fan blades for dust buildup and clean if necessary.	X			
2	Check fan blades and moving parts for cracks and excessive wear.	X			
3	Tighten all electrical connectors to proper torque as needed.	X			
4	Check that the fan runs properly in all speeds as applicable.	X			
5	Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary.	X			
7	Lubricate mechanical connections of dampers sparingly as applicable.	X			
8	Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a CM.	X			
9	Clean coils by brushing, blowing, vacuuming	X			
10	Check coils for leaking, tightness of fittings.	X			
11	Use fin comb to straighten coil fins as needed.	X			
12	Check belts for wear and cracks, adjust tension or alignment as applicable. Replace belts when necessary.	X			
13	Check rigid couplings for alignment on direct drives, and for tightness of assembly	X			
14	Vacuum interior of unit.	X			
15	Check filter door for proper gasketing and air leaks. Correct as needed.	X			
16	Change the filter as needed with the correct size and type filter.	X		Filter gets checked Quarterly	
17	Insure that drain(s) are clear and running. - Install condensate tablet	X			
18	Clean up work area. - Record Humidity level in area	X		Humidity <u>35</u> %	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: