

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
OUTDOOR CONDENSING UNIT

SITE AND BLDG #: **NY052N01**

MECHANIC
SIGNATURE: James R Groft Jr

DATE: **05/28/2025**

LOCATION/RM #: **WO# 18667** **ASSET # 3241**

START TIME: _____

FINISH TIME: _____

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
		YES	NO	SPECIAL INSTRUCTIONS	
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Remove debris from air screen and clean underneath unit.	X			
2	Wash coil with coil cleaning solution - Rinse Thoroughly	X			
3	Straighten fin tubes with fin comb, as needed.	X			
4	Check electrical connections for tightness.	X			
5	Check mounting base for tightness.	X			
6	Inspect fans for bent blades, unbalance, excessive noise and vibrations.	X			
7	Inspect all piping for leaks and tighten loose connections.	X			
8	Check wires at condenser electrical fused safety switches for tightness and burned insulation. Repair as necessary.	X			
9	Check supply air temperature to ensure unit is operating properly. If possible record room temperature and Humidity		X	N/A	Room temp _____ %
10	Inspect unit for overall condition and recommend for replacement or other needed repairs.	X			
11	Clean up work area.	X			



Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes: