

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
TIME CLOCK, LIGHTING

SITE AND BLDG #: NY058-02

**MECHANIC
SIGNATURE:**

DATE:

LOCATION/RM #:

START TIME:

FINISH TIME:

Mike wolf 8/27/19

10am

10:30am

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY058-02	4791	10190					J-43 1-pc Time Clock Rm 200	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
		YES	NO	SPECIAL INSTRUCTIONS	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	<input checked="" type="checkbox"/>			
2	Follow lock out/tag out procedures always. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		<input checked="" type="checkbox"/>		
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Clean timeclock using a soft lint-free cloth and spray bottle of glass cleaner. Remove any dirt or grease build up.	<input checked="" type="checkbox"/>			
2	Check physical connections.	<input checked="" type="checkbox"/>			
3	Verify the timeclock configuration, ensure proper operation.	<input checked="" type="checkbox"/>			
4	If applicable, check battery and replace as needed.	<input checked="" type="checkbox"/>			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct materials). For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photo of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

