

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**VARIABLE FREQUENCY DRIVE**

**SITE AND BLDG #:** NY058-02

**MECHANIC  
SIGNATURE:**

**DATE:**

*Mike Wolfe* 9/25/19

**LOCATION/RM #:**

**START TIME:**

**FINISH TIME:**

*8:30am*

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY058-02	5313	10146					J-04 1-pc Variable Frequency Drive	
NY058-02	5314	10147					J-04 1-pc Variable Frequency Drive	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	✓		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Clean VFD with vacuum	✓		
2	Tighten VFD electrical connections.	✓		
3	Verify proper operation of cooling fans and clean.	✓		
4	Ramp VFD up and down	✓		

5	Check overall condition of unit	✓		
6	Remove and dispose of any debris from any maintenance activity.	✓		
7	Document tasks performed during visit and report any observations to supervisor	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: HVAC Technician **Additional Notes:**

