

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
PLUMBING FIXTURES

ACTIVITY AND BLDG #: NY058-02

MECHANIC
 SIGNATURE: *Deen Rowe*

DATE: *7/20/21*LOCATION: *Bathroom*START TIME: *10am*FINISH TIME: *12pm*

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY058-02	13406	10174	PM-AN-10174				J-26 1-pc Janitor Sink, Floor Mounted Rm 200	
NY058-02	13407	10175	PM-AN-10175				J-26 1-pc Hand Wash Station Rm 200	
NY058-02	13408	10176	PM-AN-10176				J-26 1-pc Janitor Sink, Floor Mounted Rm 206	
NY058-02	13409	10177	PM-AN-10177				J-26 1-pc Urinal, Wet, Flush Valve Rm 205	
NY058-02	13410	10178	PM-AN-10178				J-26 1-pc Toilet, Flush Valve, Wall Mounted Rm 205	
NY058-02	13411	10179	PM-AN-10179				J-26 1-pc Lavatory, Wall Mounted Rm 205	
NY058-02	13412	10180	PM-AN-10180				J-26 1-pc Shower, Built-In Rm 205	
NY058-02	13413	10181	PM-AN-10181				J-26 2-pc Toilet, Flush Valve, Wall Mounted Rm 204	
NY058-02	13414	10182	PM-AN-10182				J-26 1-pc Lavatory, Wall Mounted Rm 204	

NY058-02 | 13415 | 10183 | PM-AN-10183 |

J-26 1-pc Shower, Built-In Rm 204

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.			
2	Review manufacturer's instructions.			
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.			
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	SINKS - Operate faucets, inspect for leaks, replace washers/"O" rings as necessary. Observe drain flow, clean trap if obstructed. Replace filter as needed.			
2	SHOWER HEADS, MIXING VALVES - Check shower for damaged, missing, or leaking heads; replace as required. Check mixing valves for damaged or missing parts; replace washers as needed.			
3	SHOWER STALLS - Check for leaks, cracks, significant wear or vandalism.			
4	TOILETS - Flush and adjust water flow if required. Inspect for leaks, missing or damaged parts/caps, seat supports, and replace.			
5	URINALS - Flush and adjust water flow if required. Inspect for leaks, missing or damaged parts/caps and replace.			
6	OTHER MISCELLANEOUS FIXTURES - Clean and inspect for any damage. Check for leaks, missing or damaged parts, caps, etc. Replace as needed.			

Note: The Contractor shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence.

Checklist compiled in accordance with:

- Original equipment manufacturers (OEM) documentation for exact or similar assets, which can be located at ([Provide Link to OEM Manual/Asset Library](#))

Additional Notes:

*Asset # 10180 has no pressure coming from shower head. (Men's Bathroom Shower).