

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**GLYCOL FEEDER**

**SITE AND BLDG #:** NY058-02

**MECHANIC  
SIGNATURE:**

*Don Rowe* **DATE:** 11/17/21

**LOCATION/RM #:** Boiler Room

**START TIME:** 11am

**FINISH TIME:** 12pm

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY058-02	14995	10158	PM-QT-10158		GF-1A1A1B	q8-533	J-12 1-pc Glycol Feed tank	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	<b>Tank and Plumbing:</b> Periodic checking of the piping and tubing is required to insure proper discharge of the glycol solution. The Y-strainer and check valve should be periodically checked for clogging and wear.	✓		
2	<b>Gear Pump:</b> Check pump for proper operation and properly lubricate as needed.	✓		
3	<b>Pressure Switch:</b> Check for wear on the contacts. Replace if damaged or worn.	✓		
4	<b>Pressure Relief Valve:</b> Check the diaphragm and seal for damage or wear. Replace as needed.	✓		

**Additional Notes:**

