

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**CHEMICAL BYPASS/POT FEEDER**

SITE AND BLDG #: NY058-02

MECHANIC  
SIGNATURE: *Dean Rose*

DATE: 11/17/21

LOCATION/RM #: *Boiler Room*

START TIME: 1 pm

FINISH TIME: 130 pm

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY058-02	14998	10161	PM-QT-10161		C0990G-2		J-12 1-pc Chemical feeder tank	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓	/	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓	/	
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Check physical condition of feeder. Clean and/or repair as needed.	✓	/	
2	Check valves for proper operation. Ensure no leaks are present and repair as needed.	✓	/	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

