

# PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

## THERMOSTATS

SITE AND BLDG #: NY058-02

LOCATION/RM #: Vehicle Bay / Office / Telecom Room

MECHANIC  
SIGNATURE: Deen Rose

DATE: 4/11/22

START TIME: 8am

FINISH TIME: 10am

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY058-02	16673	10165	PM-AN-10165	Honeywell			J-17 6-pc Thermostat, Digital Throughout	
NY058-02	16674	10166	PM-AN-10166	Liebert			J-17 1-pc Thermostat, Digital Rm 207	
NY058-02	16675	10167	PM-AN-10167	Honeywell			J-17 1-pc Thermostat, Analog Rm 210	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	✓		
2	Always follow lock out/tag out procedures. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	If EMS (Energy Management System) If it is EMS controlled 1-We log into computer with user name and password for EMS or DDC obtained from site personnel. 2-Validate set point and actual temp at computer	✓	✓	Not connected to tms / bms
2	Review all zone set points at the server IF Applicable	✓		
3	Inspect thermostat installation; ensure mounting is correct, fastened secure and that the thermostat is not blocked by equipment generating heat or furniture blocking air circulation.	✓		
4	Remove thermostat cover and lightly blow away any accumulated dust with canned low-pressure air.	✓		
5	If applicable, replace battery as needed.	✓		

6	Use our own Temperature meter to validate the computer is correct. If it is not EMS or DDC controlled take our temperature meter and check against actual thermostat and record temperature	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
---	---	-------------------------------------	--------------------------	--------------------------

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

**Additional Notes:**