

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
CHEMICAL BYPASS/POT FEEDER

SITE AND BLDG #: NY058-02

**MECHANIC
SIGNATURE:** *Deen Rane*

DATE: 8/16/22

LOCATION/RM #: *Boiler Room*

START TIME: 9:15 AM

FINISH TIME: 10:15 AM

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY058-02	18338	10158	PM-QT-10158		GF-1A1A1B	q8-533	J-12 1-pc Glycol Feed tank	
NY058-02	18341	10161	PM-QT-10161		C0990G-2		J-12 1-pc Chemical feeder tank	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check physical condition of feeder. Clean and/or repair as needed.	✓		
2	Check valves for proper operation. Ensure no leaks are present and repair as needed.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

