

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
GLYCOL FEEDER

SITE AND BLDG #: NY058-02

LOCATION/RM #: Boiler Room

MECHANIC
SIGNATURE: Deen Rose

DATE: 11/17/22

START TIME: 2:30pm

FINISH TIME: 3pm

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY058-02	19535	10158	PM-QT-10158		GF-1A1A1B	q8-533	J-12 1-pc Glycol Feed tank	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Tank and Plumbing: Periodic checking of the piping and tubing is required to insure proper discharge of the glycol solution. The Y-strainer and check valve should be periodically checked for clogging and wear.	✓	/	
2	Gear Pump: Check pump for proper operation and properly lubricate as needed.	✓	/	
3	Pressure Switch: Check for wear on the contacts. Replace if damaged or worn.	✓	/	
4	Pressure Relief Valve: Check the diaphragm and seal for damage or wear. Replace as needed.	✓	/	

Additional Notes: