

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST **TIME CLOCK, LIGHTING**

SITE AND BLDG #: NY ⁰²³⁻¹²³ ~~023-123~~

MECHANIC SIGNATURE: Deen Rose DATE: 11/9/22

LOCATION/RM #: Mailway

START TIME: 2pm FINISH TIME: 2:15pm

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY058-02	19541	10190	PM-QT-10190				J-43 1-pc Time Clock Rm 200	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓	/	
2	Follow lock out/tag out procedures always. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓	/	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Clean timeclock using a soft lint-free cloth and spray bottle of glass cleaner. Remove any dirt or grease build up.	✓	/	
2	Check physical connections.	✓	/	
3	Verify the timeclock configuration, ensure proper operation.	✓	/	
4	If applicable, check battery and replace as needed.	✓	/	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**