

PREVENTIVE MAINTENANCE PROGRAM CHECKLIST

Chemical Feeder

SITE AND BLDG#: NY058-02

MECHANIC

SIGNATURE: SIGNATURE ON FILE (DROWE)

DATE: 5/10/23

Site Location	WO#	Asset#	PM#	Manufacturer	Model Number	Serial#	Asset Description	Asset Location
NY058-02	2-21922		PM-QT-10158					

CHECK POINT	CHECKPOINT DESCRIPTION	NOTES/ACTIONS (if Task Complete is Checked 'NO', Then Provide Explanation)
		TO BE PERFORMED AT EACH INSPECTION SERVICE
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	
3	Tank and Plumbing: Periodic checking of the piping is required to insure proper discharge of the glycol solution. The Ystrainer and check valve should be periodically checked for clogging and wear.	
4	Gear Pump: Check pump for proper operation and properly lubricate as needed	
5	Pressure Switch: Check for wear on the contacts. Replace if damaged or worn.	
6	Pressure Relief Valve: Check the diaphragm and seal for damage or wear. Replace as needed.	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: