

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
UNIT HEATER, HOT WATER

SITE AND BLDG #: NY058-02

**MECHANIC
SIGNATURE:** *Dean Rowe*

DATE: 2/13/20

LOCATION/RM #: *Boiler Room*

START TIME: 11Am

FINISH TIME: 12 pm

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY058-02	7042	10184	PM-QT-10184	Rheem	ES120-24-G	AC0112D071 1RR061 1E00277	J-27 1-pc Water Heater Inventory Rm 210	
NY058-02	7043	10185	PM-QT-10185	Rheem	ES120-24-G	AC0112D071 1RR071 1E00133	J-27 1-pc Water Heater Inventory Rm 210	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓		
2	Schedule shutdown with operating personnel.	✓		
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check valve for full stroke operation in both directions, if applicable.	✓		
2	Check valve for signs of abnormal wear and leaks. Replace packing if needed.	✓		

3	Clean the coil with vacuum cleaner.	<input checked="" type="checkbox"/>		
4	Comb the fins as needed.	<input checked="" type="checkbox"/>		
5	Clean all fans and motors.	<input checked="" type="checkbox"/>		
6	Check operation of controls and safeties.	<input checked="" type="checkbox"/>		
7	Lubricate as required.	<input checked="" type="checkbox"/>		
8	Check all motors, belts, pulleys, shafts, etc. for alignment.	<input checked="" type="checkbox"/>		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

