

PREVENTIVE MAINTENANCE PROGRAM CHECKLIST

EMERGENCY LIGHTING, CLOSED SYSTEMS

SITE AND BLDG#: NY058-03

MECHANIC
SIGNATURE: SIGNATURE ON FILE (DROWE)

DATE: 8/7/23

Site Location	WO#	Asset#	PM#	Manufacturer	Model Number	Serial#	Asset Description	Asset Location
NY058-03	2-23492		PM-QT-10208					
CHECK POINT	CHECKPOINT DESCRIPTION				NOTES/ACTIONS (if Task Complete is Checked 'NO', Then Provide Explanation)			
TO BE PERFORMED AT EACH INSPECTION SERVICE								
1	Inspect for structural defects and deposits							
2	Clean off corrosion deposits and apply silicone grease to terminals							
3	Push test buttons and observe light operation (See manufacturer's instructions)							
4	Check vent holes							
5	Clean exterior with dry cloth							
6	Disconnect power to check operation The battery shall maintain the light output for 15 hours If it does not, it needs to be replaced							
7	Record battery cell voltage Replace cells below manufacturer's recommended low level							
8	If unit has to be discarded, review the Safety Data Sheet (SDS) for proper disposal of battery and electrolyte							
9	Clean up work area							
10	For Exit lights check for proper arrow direction							

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: