

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

FIRE WATER SUPPLY PUMP

SITE AND BLDG #: NY058-07

MECHANIC SIGNATURE: *Deen Rowe*

DATE: 8/19/21

LOCATION/RM #: Building 07

START TIME: 8Am

FINISH TIME: 930Am

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY058-07	14255	10215	PM-SA-10215	WeG	030180Y3E286TS		J-28 1-pc Fire Water Supply pump	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
3	It is generally not a good idea to tamper with pumps using mechanical seals if they are otherwise performing properly. Since mechanical seals can cost as much as the pump, it is usually not cost effective to risk damaging the seal by performing an annual internal inspection of the pump.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Lubricate pump and motor bearings as per manufacturer's specifications. Bearings require lubrication at least annually.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
2	Inspect couplings and check for any pump seal leaks.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
3	Check motor mounts and vibration pads	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
4	Tighten all pump flanges.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	

5	Visually check pump alignment and coupling	✓		
6	Inspect electrical connections	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

