

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
TIME CLOCK, LIGHTING

SITE AND BLDG #: NY058-104

MECHANIC
SIGNATURE:

DATE: 5/28/19

LOCATION/RM #:

START TIME:

7:00

FINISH TIME: 2:00

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY058-104	3499	10332					J-43 1-pc Time Clock - Interior Rm 149	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
		YES	NO	SPECIAL INSTRUCTIONS	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.				
2	Follow lock out/tag out procedures always. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.				
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Clean timeclock using a soft lint-free cloth and spray bottle of glass cleaner. Remove any dirt or grease build up.				
2	Check physical connections.				
3	Verify the timeclock configuration, ensure proper operation.				
4	If applicable, check battery and replace as needed.				

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct materials) during the PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photo, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

