

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**TANKS, WATER STORAGE**

SITE AND BLDG #: NY058-104

MECHANIC  
SIGNATURE: *DeN*

DATE: *2/26/21*

LOCATION/RM #: *Boiler Room*

START TIME: *9Am*

FINISH TIME: *10Am*

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY058-104	11618	10259	PM-QT-10259				J-12 1-pc Pressure Tank	
NY058-104	11619	10260	PM-QT-10260		GF-1A1A1B	qa-578	J-12 1-pc Glycol feed tank	
NY058-104	11795	10264	PM-SA-10264	Omnitec	OEL8000IIP	EL112899B	J-16 1-pc Boiler Control Panel tank monitoring	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Examine exterior of tank including fittings, manholes, and handholes for leaks, signs of corrosion, and correct as indicated.			

2	Inspect structural supports and repair or replace damaged insulation or covering. If insulation contains asbestos and is damaged or eroded, it is considered a hazardous waste.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
3	Clean, test and inspect sight glasses, valves, fittings, drains, and controls.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
4	Clean up work site.	<input type="checkbox"/>	<input type="checkbox"/>	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**