

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST WEAPON SIMULATOR IN USE SIGN

SITE AND BLDG #: NY058-104 MECHANIC SIGNATURE: Dean Rowe DATE: 2/24/21

LOCATION/RM #: Cayls START TIME: 3pm FINISH TIME: 330pm

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY058-104	11629	10337					J-47 2-pc Weapon Simulator In Use Sign	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	☒		
2	Schedule and coordinate work with operating personnel.	☒		
3	Follow lock out/tag out procedures always. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	☒		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Open and tag switch.	☒		
2	Inspect visual condition of wiring. Look for evidence of overheating.	☒		
3	Check for proper light operation.	☒		
4	Test operation of automatic switches/ time clock/ photocells if applicable.	N	A	
5	Inspect light pole and mounting devices for deficiencies.	N	A	
6	For any noted deficiency, takes pictures and open corrective maintenance ticket.	☒		



* Got Access but can't locate switch to turn on "In Use" sign.
* Can't tell if its working.

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**