

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**GLYCOL FEEDER**

**SITE AND BLDG #:** NY058-104

**LOCATION/RM #:** Boiler / Mechanical Room

**MECHANIC SIGNATURE:** DEFW Rowe

**DATE:** 25/10/21

**START TIME:** 330 pm

**FINISH TIME:** 430 pm

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY058-104	12564	10276	PM-AN-10276	Aero-Power		SCEHS # 14	J-22 1-pc # 2 Fuel Oil Tank	
NY058-104	12627	10255	PM-QT-10255	Taco	FL1509E2EA J1L OV	EC618759	J-12 1-pc Glycol Heating Supply Pump	
NY058-104	12628	10256	PM-QT-10256	Taco	FL1509E2EA J1L OV	EO618759	J-12 1-pc Glycol Heating Supply Pump	
NY058-104	12630	10259	PM-QT-10259				J-12 1-pc Pressure Tank	
NY058-104	12631	10260	PM-QT-10260		GF-1A1A1B	qa-578	J-12 1-pc Glycol feed tank	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS
		YES	NO	
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	<b>Tank and Plumbing:</b> Periodic checking of the piping and tubing is required to insure proper discharge of the glycol solution. The Y-strainer and check valve should be periodically checked for clogging and wear.	✓		
2	<b>Gear Pump:</b> Check pump for proper operation and properly lubricate as needed.	✓		

3	<b>Pressure Switch:</b> Check for wear on the contacts. Replace if damaged or worn.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	<b>Pressure Relief Valve:</b> Check the diaphragm and seal for damage or wear. Replace as needed.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**Additional Notes:**

