

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**CIRCULATING AND BOOSTER PUMPS**

SITE AND BLDG #: NY058-104

MECHANIC  
SIGNATURE: *Deen Rowl*

DATE: 05/20/21

LOCATION/RM #: *Boiler / Mechanical Room*

START TIME: 11Am

FINISH TIME: 12pm

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY058-104	12626	10254	PM-QT-10254	Taco		f0912021699	J-12 2-pc Chill Water Pump	
NY058-104	12629	10257	PM-QT-10257	Baldor Reliance			J-12 5-pc Hot Water Pump	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓	/	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓	/	
3	It is generally not a good idea to tamper with pumps using mechanical seals if they are otherwise performing properly. Since mechanical seals can cost as much as the pump, it is usually not cost effective to risk damaging the seal by performing an annual internal inspection of the pump.	✓	/	
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Lubricate pump and motor bearings as per manufacturer's specifications. Bearings require lubrication at least annually.	✓	/	

2	Inspect couplings and check for any pump seal leaks.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
3	Check motor mounts and vibration pads	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
4	Tighten all pump flanges.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
5	Visually check pump alignment and coupling	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
6	Inspect electrical connections	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

