

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
LIGHTING, OUTSIDE

SITE AND BLDG #: NY058

MECHANIC:

Deen Rowt

6/23/21

LOCATION/RM #: Exterior Building 104

SIGNATURE:

DATE:

START TIME: 5pm

FINISH TIME: 6pm

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY058-104	13040	10335	PM-MO-10335	Metal Halide			J-45 4-pc Double Light, Pole Mounted Military Equipment Parking	
NY058-104	13041	10336	PM-MO-10336	High Press Sodium			J-45 10-pc Motor Vehicle Area Light Military Equipment Parking	
NY058-104	13123	10333	PM-SA-10333	Metal Halide			J-44 4-pc Double Light, Pole Mounted POV Parking Area lights	
NY058-104	13124	10334	PM-SA-10334	High Press Sodium			J-44 10-pc Motor Vehicle Area Light POV Parking Area lights	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
		YES	NO	SPECIAL INSTRUCTIONS	
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓	/		
2	Schedule and coordinate work with operating personnel.	✓	/		
3	Follow lock out/tag out procedures always. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓	/		

1	Open and tag switch.	✓			
2	Inspect visual condition of wiring. Look for evidence of overheating.	✓			
3	Check for proper light operation.	✓			
4	Test operation of automatic switches/ time clock/ photocells if applicable.	✓			
5	Inspect light pole and mounting devices for deficiencies.	✓			
6	For any noted deficiency, takes pictures and open corrective maintenance ticket.	✓			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

