

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
GLYCOL FEEDER

SITE AND BLDG #: NY058-104

LOCATION/RM #: Boiler Room

**MECHANIC
SIGNATURE:** *Ben Rowe*

DATE: 11/18/21

START TIME: 9:30 AM

FINISH TIME: 10:30 AM

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY058-104	15011	10260	PM-QT-10260		GF-1A1A1B	qa-578	J-12 1-pc Glycol feed tank	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Tank and Plumbing: Periodic checking of the piping and tubing is required to insure proper discharge of the glycol solution. The Y-strainer and check valve should be periodically checked for clogging and wear.	✓		
2	Gear Pump: Check pump for proper operation and properly lubricate as needed.	✓		
3	Pressure Switch: Check for wear on the contacts. Replace if damaged or worn.	✓		
4	Pressure Relief Valve: Check the diaphragm and seal for damage or wear. Replace as needed.	✓		

Additional Notes:

* CM- Light Fixture Above Ballast is out.

