

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**TIME CLOCK, LIGHTING**

**SITE AND BLDG #:** NY058-104

**MECHANIC  
SIGNATURE:** *Den Rowe*

**DATE:** 2/23/21

**LOCATION/RM #:** 151 electrical Room

**START TIME:** 2:30pm

**FINISH TIME:** 2:45pm

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY058-104	16049	10332	PM-QT-1033 2				J-43 1-pc Time Clock - Interior Rm 149	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓		
2	Follow lock out/tag out procedures always. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Clean timeclock using a soft lint-free cloth and spray bottle of glass cleaner. Remove any dirt or grease build up.	✓		
2	Check physical connections.	✓		
3	Verify the timeclock configuration, ensure proper operation.	✓		
4	If applicable, check battery and replace as needed.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

