

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**GATES**

SITE AND BLDG #: NY058-104MECHANIC SIGNATURE: *Deen Rowe*DATE: *4/13/22*LOCATION/RM #: *Entrance*WO# *16782*ASSET # *10342*START TIME: *1pm*FINISH TIME: *130pm*

Site Location	WO#	Asset #	PM #	Manufacturer	Model Number	Serial #	Description	Asset Location
NY058-104	16782	10342	PM-MO-10342	Powermaster	SG102	LAH5513 36	J-49 1-pc Single Gate, Automatic, Sliding Site Entrance	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
2	Notify affected personnel before performing PM	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Inspect all pivot points, hinges, latches, etc. Apply lubricant where needed, wiping off excess.	✓		
2	Check all locking devices. Lubricate as required.	✓		
3	Inspect gate support rollers and track, lubricate and clean as required.	✓		
4	Check bolts, fasteners, and mounting hardware. Tighten as necessary.	✓		
5	Check for any obstructions that prevent full swing or movement of the gate.	✓		
6	Check that shrubs and trees are pruned clear of gate.	✓		
7	Check hold open devices for proper operation. Lubricate as required.	✓		

8	Check the top guard and ensure that it is properly fastened and the wires are tight. Tighten as required.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	If applicable, inspect hydraulic driveline (hoses, fittings, and gauges) for signs of leakage.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10	If applicable, inspect limit switches for proper operation. Adjust as needed.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	If applicable, inspect photoeyes for proper operation and any signs of damage.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	If applicable, have site personnel operate gate with CAC Card insuring proper operation.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13	If applicable, clean control cabinet, ensuring free from debris and insects.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:**

Passcode / No CAC access