

# PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

## LIGHTING, OUTSIDE

SITE AND BLDG #: NY058-104

MECHANIC:

DEEN ROWE

5/11/22

SIGNATURE:

DATE:

LOCATION/RM #: Outside Bldg. 104

START TIME: 3pm

FINISH TIME: 4pm

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY058-104	16937	10335	PM-MO-10335	Metal Halide			J-45 4-pc Double Light, Pole Mounted Military Equipment Parking	
NY058-104	16938	10336	PM-MO-10336	High Press Sodium			J-45 10-pc Motor Vehicle Area Light Military Equipment Parking	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓	✓	
2	Schedule and coordinate work with operating personnel.	✓	✓	
3	Follow lock out/tag out procedures always. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓	✓	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Open and tag switch.	✓	✓	
2	Inspect visual condition of wiring. Look for evidence of overheating.	✓	✓	
3	Check for proper light operation.	✓	✓	
4	Test operation of automatic switches/ time clock/ photocells if applicable.	✓	✓	
5	Inspect light pole and mounting devices for deficiencies.	✓	✓	
6	For any noted deficiency, takes pictures and open corrective maintenance ticket.	✓	✓	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**