

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
OUTDOOR CONDENSING UNIT

SITE AND BLDG #: NY058-104

MECHANIC
SIGNATURE: *Deen Rowe*

DATE: *9/26/22*

LOCATION/RM #: *Outside Building 104*

START TIME: *5am*

FINISH TIME: *12pm*

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY058-104	19041	10237	PM-SA-10237	Liebert	PFH014A-PL7	1031N201486	J-04 1-pc Condensing Unit	
NY058-104	19042	10238	PM-SA-10238	Liebert		1031n201486	J-04 1-pc Condensing Unit	
NY058-104	19043	10239	PM-SA-10239	Liebert	PFH027-PL7	1031N201589	J-04 1-pc Condensing Unit	
NY058-104	19044	10240	PM-SA-10240	Liebert	PFH027A-PL7	1031N21519	J-04 1-pc Condensing Unit	
NY058-104	19045	10241	PM-SA-10241	Liebert	PFH037A-AL7	1031N201535	J-04 1-pc Condensing Unit	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
		YES	NO	SPECIAL INSTRUCTIONS	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓			
2	Schedule outage of unit with personnel in area the unit serves.	✓			
3	Follow lock out/tag out procedures always. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓			

4	If disposal of the equipment is required, follow regulations concerning removal of refrigerants and disposal of the unit.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Remove debris from air screen and clean underneath unit.	✓		
2	Wash coil with coil cleaning solution - Rinse Thoroughly	✓		
3	Straighten fin tubes with fin comb, as needed.	✓		
4	Check electrical connections for tightness.	✓		
5	Check mounting base for tightness.	✓		
6	Inspect fans for bent blades, unbalance, excessive noise, and vibrations.	✓		
7	Inspect all piping for leaks and tighten loose connections.	✓		
8	Check wires at condenser electrical fused safety switches for tightness and burned insulation. Repair as necessary.	✓		
9	Check supply air temperature to ensure unit is operating properly. If possible record room temperature.	✓		
10	Inspect unit for overall condition and recommend for replacement or other needed repairs.	✓		
11	Clean up work area.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: HVAC Technician **Additional Notes:**

Asset # 10241

CM - unit still not working needs
to be repaired ✓

CM

- Asset # 10240 needs

New condenser fan motor.