

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
GLYCOL FEEDER

SITE AND BLDG #: NY058-104

LOCATION/RM #: Boiler Room / Mechanical Room

MECHANIC
SIGNATURE: Dean Rowe

DATE: 11/23/22

START TIME: 1:30pm

FINISH TIME: 2pm

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY058-104	19547	10255	PM-QT-10255	Taco	FL1509E2E AJ1L OV	EC618759	J-12 1-pc Glycol Heating Supply Pump	
NY058-104	19548	10256	PM-QT-10256	Taco	FL1509E2E AJ1L OV	EO618759	J-12 1-pc Glycol Heating Supply Pump	
NY058-104	19551	10260	PM-QT-10260		GF-1A1A1B	qa-578	J-12 1-pc Glycol feed tank	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS	
		YES	NO		
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Tank and Plumbing: Periodic checking of the piping and tubing is required to insure proper discharge of the glycol solution. The Y-strainer and check valve should be periodically checked for clogging and wear.	✓			
2	Gear Pump: Check pump for proper operation and properly lubricate as needed.	✓			
3	Pressure Switch: Check for wear on the contacts. Replace if damaged or worn.	✓			
4	Pressure Relief Valve: Check the diaphragm and seal for damage or wear. Replace as needed.	✓			

Additional Notes:

