

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
DOMESTIC HOT WATER HEATER - ELECTRIC

SITE AND BLDG #: NY058-104

LOCATION/RM #: Mechanical Room (2nd floor)

MECHANIC
 SIGNATURE: *DeW* *Rowe*

DATE: 11/20/22

START TIME: 8Am

FINISH TIME: 11Am

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY058-104	19557	10323	PM-QT-10323	Rheem	ES120-36-G		J-27 1-pc Water Heater Inventory RM 227	
NY058-104	19558	10324	PM-QT-10324	Rheem	ES120-36-G		J-27 1-pc Water Heater Inventory RM 227	
NY058-104	19559	10325	PM-QT-10325	Rheem	ES120-36-G		J-27 1-pc Water Heater Inventory RM 227	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
		YES	NO	SPECIAL INSTRUCTIONS	
SPECIAL INSTRUCTIONS					
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓			
2	Follow lock out/tag out procedures always. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓			
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Attach drain hose. Drain several gallons from tank to remove sediment.	✓			

2	Manually check operation of safety valve. Check for corrosion around valve. Verify the safety valve inspection tag is in place. Ensure that no personnel are in area of relief piping discharge.	✓		
3	Check all connections - electric and water. Tighten as necessary. Ensure power is disconnected to electric heaters prior to checking connections.	✓		
4	Check operation/ setting of aqua stat. Check hot water temperature with dial thermometer, set aqua stat at minimum value required for all uses.	✓		
5	Check amperage draw of upper and lower elements and compare to name plate data.	✓		
6	Clean element contacts and check for proper closing under load.	✓		
7	Clean pump, controls, switches, and starters. Check condition of pump seal or packing and replace as required.	✓		
8	If applicable, Remove and inspect Anode, replace if necessary	N	A	
9	Clean up work area and remove trash.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**