

# PREVENTIVE MAINTENANCE PROGRAM CHECKLIST

## EMERGENCY GENERATORS

**SITE AND BLDG#:** NY058-104

**MECHANIC**

**SIGNATURE:** *SIGNATURE ON FILE (DROWE)*

**DATE:** 5/1/23

Site Location	WO#	Asset#	PM#	Manufacturer	Model Number	Serial#	Asset Description	Asset Location
NY058-104	2-21821		PM-AN-10276					

CHECK POINT	CHECKPOINT DESCRIPTION	NOTES/ACTIONS (if Task Complete is Checked 'NO', Then Provide Explanation)
		TO BE PERFORMED AT EACH INSPECTION SERVICE
1	Fuel (check main and day tank fuel supply levels;)	
2	Oil (check for proper oil level and oil operating pressure; lube oil heater)	
3	Oil operating pressure should normally be above 40 psi	
4	Cooling system (check coolant level, water pump(s), jacket water heater, belts, hoses, fan)	
5	Exhaust system (check drain condensate trap and for possible leakage)	
6	Battery system [look for possible corrosion; check specific gravity, electrolyte level (a level between 1250 and 1275 is acceptable) and battery charger]	
7	Electrical (conduct a general inspection of wiring and connections; check circuit breakers/fuses)	
8	Check for debris, foreign objects, loose or broken fittings; check guards and components; look for any unusual condition of vibration	

**Note:** The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

**To be performed by:** General Maintenance Worker

**Additional Notes:**