

PREVENTIVE MAINTENANCE PROGRAM CHECKLIST

DEHUMIDIFIER

SITE AND BLDG#:NY058-104

MECHANIC
SIGNATURE:SIGNATURE ON FILE (DROWE)

DATE:7/12/23

Site Location	WO#	Asset#	PM#	Manufacturer	Model Number	Serial#	Asset Description	Asset Location
NY058-104	2-23193		PM-SA-10261					

CHECK POINT	CHECKPOINT DESCRIPTION	NOTES/ACTIONS (if Task Complete is Checked 'NO', Then Provide Explanation)
TO BE PERFORMED AT EACH INSPECTION SERVICE		
1	Check water inlet for any leaks, repair as needed	
2	If applicable, check hours per usage, replace tanks's as needed	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: