

PREVENTIVE MAINTENANCE PROGRAM CHECKLIST

Weapon Simulator

SITE AND BLDG#: NY058-104

MECHANIC

SIGNATURE: SIGNATURE ON FILE (DROWE)

DATE: 8/7/23

Site Location	WO#	Asset#	PM#	Manufacturer	Model Number	Serial#	Asset Description	Asset Location
NY058-104	2-23510		PM-QT-10337					

CHECK POINT	CHECKPOINT DESCRIPTION	NOTES/ACTIONS (if Task Complete is Checked 'NO', Then Provide Explanation)
		TO BE PERFORMED AT EACH INSPECTION SERVICE
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	
2	Schedule and coordinate work with operating personnel.	
3	Follow lock out/tag out procedures always. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	
4	Open and tag switch.	
5	Inspect visual condition of wiring. Look for evidence of overheating.	
6	Check for proper light operation.	
7	Test operation of automatic switches/ time clock/ photocells if applicable.	
8	Inspect light pole and mounting devices for deficiencies.	
9	For any noted deficiency, takes pictures and open corrective maintenance ticket.	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: