

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
GATES, FENCES, SECURITY AND ACCESS

SITE AND BLDG # NY058-104

MECHANIC

Deen Rowe

12/20/19

LOCATION/RM #: Outside Building 104

SIGNATURE:

DATE:

START TIME: 8am

FINISH TIME: 9am

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY058-104	6190	10342	PM-MO-10342	Powermaster	SG102	LAH5513 36	J-49 1-pc Single Gate, Automatic, Sliding Site Entrance	
NY058-104	6273	10339	PM-SA-10339				J-49 1-pc Double Gate, Manual, Swinging Northeast Refuse Enclosure	
NY058-104	6274	10340	PM-SA-10340				J-49 1-pc Double Gate, Manual, Swinging Northeast Entrance	
NY058-104	6275	10341	PM-SA-10341				J-49 1-pc Single Gate, Manual, Swinging Northwest Across Road	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
		YES	NO	SPECIAL INSTRUCTIONS	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	✓			

2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
GATES				
1	Inspect all pivot points, hinges, latches, etc. Apply lubricant where needed, wiping off excess.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2	Check all locking devices. Lubricate as required.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
3	Inspect center gate support rollers and lubricate as required.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
4	Clean roller track of any debris.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
5	Check bolts, fasteners, and mounting hardware. Tighten or adjust as necessary.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
6	Check for any obstructions that retard full swing or movement of the gate.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
7	Check that shrubs and trees are pruned clear of gate.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
8	Check hold open devices for proper operation. Lubricate as required.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
FENCES				
1	Check posts and corner posts, support guys, and horizontal bars between each support post.	—	—	
2	Check wire and anchor point; re-stretch and re-anchor if necessary.	—	—	
3	Inspect fence anchors along the bottom of the fence and at the point where the fence is connected to the post.	—	—	
4	Treat with galvanized protectant where rust has developed.	—	—	
5	If approved, apply weed control along entire base of fence. Consult the Safety Data Sheets (SDS) for hazardous ingredients and proper personal protective equipment (PPE).	—	—	
6	Check that shrubs and trees are pruned clear of fencing	—	—	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**