

REVIEWED

By Mike Merchan at 3:09 pm, Feb 25, 2019

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
WEAPON SIMULATOR IN USE SIGN

SITE AND BLDG #: NY058-104

LOCATION/RM #: **RM 157A**MECHANIC
SIGNATURE:*swill Wolfe*DATE: **2/25/2019**START TIME: **8:30**FINISH TIME: **2PM**

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY058-104	2256	10337					J-47 2-pc Weapon Simulator In Use Sign	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)		
		YES	NO			
SPECIAL INSTRUCTIONS						
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.					
2	Schedule and coordinate work with operating personnel.					
3	Follow lock out/tag out procedures always. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.					
TO BE PERFORMED AT EACH INSPECTION SERVICE						
1	Open and tag switch.					
2	Inspect visual condition of wiring. Look for evidence of overheating.					
3	Check for proper light operation.					
4	Test operation of automatic switches/ time clock/ photocells if applicable.					
5	Inspect light pole and mounting devices for deficiencies.					
6	For any noted deficiency, takes pictures and open corrective maintenance ticket.					



Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**