

CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY0058 Date of Visit: 12/13/2019

Contractor Personnel on Site:

1. Michael Sarro 2. _____

Work Performed: Replacement of Power Pack for Occupancy Sensors Room 219.

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO# 2-6027

Service Calls – Service Call Number and Description

1. CSS# 22135
2. CSS# _____
3. CSS# _____

 Pictures are required (Before and After)

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Michael Sarro Date: 12/13/2019

Signed: 

To be signed by Facility Manager:

I certify that the above named individuals representing the Contractor arrived on site and to the best of my knowledge, completed the stated work listed:

Print Name/Rank: Ryan Linn/RFOS Date: _____

Signed: LINN.RYAN.G.1037390832 Digitally signed by LINN.RYAN.G.1037390832
Date: 2019.12.16 13:54:21 -05'00'

E-Mail: _____



MAINTENANCE
RECORD

sensor switch

sensor switch®

POWER PACK - RELAY CIRCUIT
PROTECTION: 120/277 VAC

MODEL# PP20

ENCLOSED ENERGY MANAGEMENT EQUIPMENT
120/277 VAC · 50/60 Hz · 20 Amp MAX
UL 2043 PLENUM RATED
TO BE USED WITH 15 TO 24 VDC SENSORS

Quantity 1

184CHH

1 6DXG8




DATE CODE
1218




45975 80959

Assembled in Mexico

AcuityControls



PP20
Power Pack - Relay Circuit Protection:
120/277 VAC
20 AMP MAX
UL 2043 PLENUM RATED
BLACK - 120 VAC
ORANGE - 277 VAC
WHITE - NEUTRAL
BLUE - RELAY CONTACTS
BLUE - RELAY CONTACTS
CAUTION: CAP AND TAPE OFF
ALL EXPOSED WIRE LEADS
CLASS 1
RED - 15 VDC
WHITE - SENSOR
BLACK - COMMON
CLASS 2
3062
LISTED
INDOOR USE ONLY
ENCLOSED ENERGY MANAGEMENT
EQUIPMENT
Sensor Switch, Inc. 900 Northrop Rd.
Wallingford, CT 06492
www.sensorswitch.com 1-800-
PASSIVE - Assembled in Mexico





PP20
Power Pack - Relay Circuit Protection:
120/277 VAC
120 OR 277 VAC 20 AMPS MAX
UL 2043 PLENUM RATED
CLASS 1
BLACK - 120 VAC
ORANGE - 277 VAC
WHITE - NEUTRAL
BLUE - RELAY CONTACTS
CAUTION: CAP AND TAPE OFF
ALL EXPOSED WIRE LEADS
CLASS 2
RED - 15 VDC
WHITE - SENSOR
BLACK - COMMON
INDOOR USE ONLY
ENCLOSED ENERGY MANAGEMENT
EQUIPMENT
Sensor Switch, Inc. 900 Northrop Rd.
Wallingford, CT 06492
www.sensorswitch.com - 1-800-
PASSIVE - Assembled in Mexico



7 8599113790 3
52 C1

