

ACAV SERVICES

December 30, 2019



ESTIMATE 1230191 CSS23186 WO6506

Bill To		Ship To	
Customer	International Support Group J Merchant,	Recipient	99 RSC DPW R Linn
Customer ID#	NY058 (Shoreham USARC)	Address	Ernie Pyle USARC BLDG 200 Ft Totten NY
Address	9050 Pines Blvd STE 150 Pembroke Pines FL 33024	Phone	718 631 6188
Phone	718 790 3562		
Payment Due	NET 30	Delivery Date	N/A
Salesperson	JW	Shipping Method	N/A
Payment Terms	CC	Shipping Terms	N/A

Qty.	Item#	Description	Unit Price	Line Total
1	1	<p>NY058 Shoreham USARC</p> <p>BMS SYSTEM NOT RESPONDING</p> <p>HEATING SYSTEM NOT</p> <p>RESPONDING</p> <p>BMS SYSTEM NEEDS AN</p> <p>EXTENSIVE UPGRADE (Quote was</p> <p>sent to the 99th RSC 30 Oct 2019)</p> <p>CHECK HOT WATER COIL IN AHU-1-T</p> <p>CHECK SUPPLY AIR SET POINT</p> <p>FROM 60 TO 65</p>		

ACAV Services

11 Snug Cove Lane
Bayville NY 11709
Jacka377@verizon.net
516 941 6581

Qty.	Item#	Description	Unit Price	Line Total
		CHECK SET POINTS ON AS AHU-2-T CHECK HOT WATER SYSTEM CHECK ALL UNIT HEATERS		
		Material		\$225.00
		Labor 8 hours @ \$190.00 per hour		\$1520.00
		TOTAL		\$1745.00
				TOTAL \$1745.00