

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

REACH-IN REFRIGERATORS/ FREEZERS

SITE AND BLDG #: NY065-01
LOCATION/RM #: 6865
WO# 19678 **ASSET #** 6895

MECHANIC SIGNATURE: Bill Davis

DATE: 8/5/25

START TIME: **FINISH TIME:**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	De-energize, lock out, and tag electrical circuits.	•		
2	If appliance is disposed, follow regulations concerning removal of refrigerants and disposal of the appliance.	•		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check with operating or area personnel for any deficiencies; verify cleaning program.	•		Asset 6865 Traulsen has been replaced. New manufacturer Norlake Model AdvantEdge R23-S Serial #R23S-15090027 
2	Verify indicator light on; check compartment temperature.	•		
3	Examine evaporator for proper clearances/slope and air flow.	•		
4	Examine handles, hinges and tightness of door closure.	•		
5	Examine safety door release and fan shut down safety switch.	•		
6	Inspect lighting for burnt out lamps. Replace if required.	•		
7	Clean evaporator coil, evaporator drain pan, blowers, fans, motors, and drain piping as required; lubricate motor(s).	•		
8	Clean condenser coil and condensing unit section.	•		
9	Clean and inspect defrost evaporation trays/pans.	•		
10	Check operation of thermostats; calibrated as required.	•		
11	Check coil superheat and adjust to manufacturers recommendations.	•		
12	Inspect and service all electric motors.	•		
13	Check box floor for water or ice accumulation.	•		
14	Clean up area and note any deficiencies.	•		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

Asset 6895 is condemned for removal. Continental 6 refrigerator C78-25-65 Serial 49806646. Continental was replaced. Replacement is out of service and being removed.

