

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

OUTDOOR CONDENSING UNIT

SITE AND BLDG #: NY070N01

MECHANIC


SIGNATURE: James R Groft JrDATE: 11/13/2024

LOCATION/RM #:

WO# 17010ASSET # 3229

START TIME:

FINISH TIME:

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
		YES	NO		
SPECIAL INSTRUCTIONS					
1	Schedule outage of unit with personnel in area the unit serves.	X			
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	X			
3	If disposal of the equipment is required, follow regulations concerning removal of refrigerants and disposal of the unit.	X			
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Remove debris from air screen and clean underneath unit.	X			
2	Wash coil with coil cleaning solution - Rinse Thoroughly	X			
3	Straighten fin tubes with fin comb, as needed.	X			
4	Check electrical connections for tightness.	X			
5	Check mounting base for tightness.	X			
6	Inspect fans for bent blades, unbalance, excessive noise and vibrations.	X			
7	Inspect all piping for leaks and tighten loose connections.	X			
8	Check wires at condenser electrical fused safety switches for tightness and burned insulation. Repair as necessary.	X			
9	Check supply air temperature to ensure unit is operating properly. If possible record room temperature.and Humidity	X			Room temp <u>69</u> Room Humidity <u>34</u> %
10	Inspect unit for overall condition and recommend for replacement or other needed repairs.	X			
11	Clean up work area.	X			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes: