












**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**AIR COOLED CHILLER, PACKAGE UNIT**

SITE AND BLDG #: **NY070N01**
**MECHANIC**  
**SIGNATURE:**James R Groft Jr
**DATE:** 05/30/2025
**LOCATION/RM #:** **WO#18654**      **ASSET #3209**
**START TIME:**      **FINISH TIME:**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)		
		YES	NO	SPECIAL INSTRUCTIONS		
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	X		    		
2	No intentional venting of refrigerants is permitted. During the servicing, maintenance, and repair of refrigeration equipment, the refrigerant must be recovered.	X		    		
3	Whenever refrigerant is added or removed from equipment, record the quantities on the appropriate forms. Forms to be maintained by technician in universal waste binder.	X		    		
4	Recover, recycle, or reclaim the refrigerant as appropriate.	X		    		
5	If disposal of the equipment item is required, follow regulations concerning removal of refrigerants and disposal of the item.	X		    		
6	If materials containing refrigerants are discarded, comply with EPA regulations as applicable.	X		    		
7	Refrigerant oils to be treated as hazardous waste.	X		    		
8	Closely follow all safety procedures described in the Safety Data Sheet (SDS) for the refrigerant and all labels on refrigerant containers.	X		    		
9	Remove access covers prior to accomplishing check points.	X				
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>						
<b>CONDENSER</b>						
1	Remove debris from air screen and clean underneath unit.	X		    		
2	Pressure wash coil with proper cleaning solution.	X		    		
3	Straighten fin tubes with fin comb.	X		    		
4	Check electrical wiring and tighten loose connections. Check fused disconnect switches for condition and operation, contactors	X		    		
5	Check mounting for tightness.	X		    		
6	Check for corrosion. Clean and treat with inhibitor as needed.	X				
7	Check fan or blower for bent or damaged blades and imbalance.	X				

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
		YES	NO		
8	Lubricate shaft and motor bearings on fans and remove old or excess lubricant, if applicable.	X			
9	Inspect pulleys, belts, couplings, etc.; adjust tension and tighten mountings as necessary. Change badly worn belts. Multi-belt drives should be replaced with matched sets.	X			
<b>EVAPORATOR</b>					
1	Inspect evaporator for any obvious deficiencies.	X			
2	Inspect plumbing, valves and flanges for leaks and correct as needed.	X			
<b>COMPRESSOR(S)</b>					
1	Lubricate drive coupling, if applicable.		X	N/A	
2	Lubricate motor bearings (non-hermetic), if applicable.		X	N/A	
3	Check bearings for vibrations or unusual noises.	X			
4	Leak test unit with soap test or electronic device.	X			
5	Check compressor oil level., if applicable.	X			
6	Run machine; check action of controls, relays, switches, etc. to see that: a. Compressor(s) run at proper settings. b. Suction and discharge pressures are proper.	X			
7	Check vibration eliminators. Replace as necessary.	X			
8	Document AMP draw on compressors	X		L1 20.6	L2 21.1 L3 20.7
9	Check safety controls for high pressure cut off.	X			
<b>CONTROLS</b>					
1	Record chilled water supply and return temps and Humidity .		X	N/A	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

**Additional Notes:**