PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FILTER REPLACEMENT

SITE AND BLDG #: NY070N02

MECHANIC SIGNATURE: James R Groft

DATE: 02/20/2026

LOCATION/RM #:

WO# 21001

START TIME:

FINISH TIME:

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE YES	TASK COMPLETE NO	NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check, clean, and/or replace filters as required.	X		
2	Initial and Date Filter (if disposable)	X		
3	Initial and Date Yellow Maintenance Tag (if applicable)	X		

ASSET #	SIZE	QTY	NOTES/ ACTIONS
3352	Record Size : 20 X 20 X 2	4	
	NOTE : Any AHU with outside air -Filter gets replaced Quarterly		
	All other filters get replaced annually But inspected Quarterly		

Note: The technician shall perform any repairs identified during PM up to $250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding $250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes: