

March checklists 2021

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST SUMP PUMP

SITE AND BLDG #: **ny116-02**

MECHANIC SIGNATURE: **Ramon V**

DATE: **3-25-2021**

LOCATION/RM #: **WO# 12046**

ASSET # **10769**

START TIME:

FINISH TIME:

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		SPECIAL INSTRUCTIONS	NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO		
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.				
2	Schedule outage with operating personnel.				
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.				missing asset.no sump pump in the building.
4	If the material removed from the pump is hazardous, contact the Regional S&EM office for disposal instructions.				
5	If strainer cleaning requires removal of pump unit which should be considered a repair and not general maintenance.				
6	Excessive sediment and debris, not removed by flushing the pit should be handled on a project basis, and not considered under this standard.				
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Remove cover plates and flush pit.				
2	Inspect check valve.				
3	Inspect interior of pit for cracks.				
4	Inspect cover plate gaskets and replace if necessary.				
5	Insuare the unit is operating properly, report any deficiencies				
6	Clean up work area and remove all debris.				

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: