

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
ENERGY RECOVERY VENTILATOR

SITE AND BLDG #: <u>NY126N01</u>		MECHANIC SIGNATURE: <u>James R Groft Jr</u>		DATE: <u>02/06/2025</u>
LOCATION/RM #: <u>WO# 17701</u> ASSET # <u>3137</u>		START TIME:		FINISH TIME:
CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>		ERV-1
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check all moving components for proper lubrication. Apply lubrication where required.	<input checked="" type="checkbox"/>		
2	Check dampers to ensure they open and close properly.	<input checked="" type="checkbox"/>		
3	Check all fan belts for wear, tension, alignment, and dirt accumulation.	<input checked="" type="checkbox"/>		
4	Check fan wheels and fasteners for oil and dust accumulation and clean as necessary.	<input checked="" type="checkbox"/>		
5	Check, clean, and/or replace both internal and external filters as necessary.	<input checked="" type="checkbox"/>		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes: