

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST FILTER REPLACEMENT




SITE AND BLDG #: NY126N01

MECHANIC SIGNATURE: James R Groft

DATE: 02/27/2026

LOCATION/RM #: WO# 20991 3118 3137 3143 3164

START TIME: _____ **FINISH TIME:** _____

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check, clean, and/or replace filters as required.	X		
2	Initial and Date Filter (if disposable)	X		
3	Initial and Date Yellow Maintenance Tag (if applicable)	X		
ASSET #	SIZE	QTY		NOTES/ ACTIONS
	Record Size : 20 x 24 x 2	15		
	20 x 20 x 2	15		
				
				
	NOTE : Any AHU with outside air -Filter gets replaced Quarterly			
	All other filters get replaced annually But inspected Quarterly			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes: