

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
AIR HANDLER

SITE AND BLDG #: NY023-123

MECHANIC
SIGNATURE:

Daren

DATE: *6/30/22*

LOCATION/RM #: *Arms Room*

START TIME: *8pm*

FINISH TIME: *8pm*

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
NY023-123	17326	9337	PM-FQT-9337	Carrier			J-04 1-pc Air Handler	

BELT SIZE

QTY

FILTER SIZE

QTY

*****Make, Model and Serial number must be filled out and corrected if applicable.*****

Before and After Pictures Required

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Check/Lubricate blower and motor bearings			
2	Check operating voltage-indicate voltage in note section			
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check amperage-indicate voltage in note section			

2	Visually check control valve(s)			
3	Check operation of control valve(s)			
4	Check condition of coils			
5	Visually inspect for coil leaks			
6	Visually inspect for piping leaks			
7	Check for deterioration of gaskets			
8	Record differential temperatures			
9	Record differential pressures			
10	Check starter/contactor			
11	Check and tighten electrical connections			
12	Clean condensate pan and clear drain line			
13	Check overall condition of unit- include year of model in note section			

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
14	Inspect and Change belt if needed- indicate size in note section			
15	Change filter- indicate size in note section			
16	Check integrity of cabinet hardware			
17	Inspect motor mounting isolators			
18	Check condition of pulley and belts			
19	Check pulley alignment			

20	Remove and dispose of any debris from any maintenance activity	✓	✓	
21	Document tasks performed during visit and report any observations to supervisor	✓	✓	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: HVAC Technician **Additional Notes:**

* Personnel with Access to Arms Room is deployed, can not access Arrest # 9337.