



TO: CMI
5285 Shawnee Road
Suite 510
Alexandria, VA

June 9, 2021

RE: CSS 30341/WO12872 Additional findings

United Air Conditioning to provide necessary labor and materials to perform the following work at the NYANG Recruit Center, 910 Raz Avenue, New Windsor, NY, per findings on our Service Order # 428446, dated 6/7/21

During agreed repairs per aforementioned WO, technician discovered additional leak and suggested necessary repairs to better support piping for AH#4 chilled water line as follows:

INCLUDES:

- Isolate and repair leak
- Install additional strut, rod and clamp to better support supply line, including reinstallation of insulation
- Check system operation

EXCLUDES:

- Overtime labor
- SO#: 428446
- Any additional labor and materials deemed necessary once above referenced work is performed

Labor: 12 hours X \$163.00/hour: \$1,956.00 (2 men, 6 hours)

Materials: Unistrut, threaded rod, \$ 300.00
8" pipe clamp,
misc. hardware(nuts/washers/etc.)

PRICE: \$2,256.00

Two thousand two hundred fifty six dollars & 00/100

PRICES EXPIRE 30 DAYS FROM DATE OF PROPOSAL

- a.) All sums due hereunder, if not paid within THIRTY (30) days of the invoice date, shall bear interest at the rate of 1.5% per month.
- b.) In the event litigation is commenced to collect any sums due hereunder, the prevailing party in such litigation shall be entitled to an award of reasonable attorney's fees.

Payments to be made as follows: NET 30

Submitted by:
United Air Conditioning, Refrigeration, Plumbing & Heating, Inc. (CD)

Sign: _____ Print: _____ Date: _____